

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:34 pm

PWS ID: UTAH21047 **Name:** GOOSEBERRY GUARD STATION
Legal Contact: USFS - FISHLAKE NATIONAL FOREST S **Rating:** Approved
MATT W VELLINGA **Rating Date:** 04/09/1996
Address: 115 E 900 N **Activity Status:** Active
RICHFIELD, UT 84701
Phone Number: 435-896-9233
City Served (Area):
County: SEVIER COUNTY
System Type: Non-community **Last Inv Update:** 02/17/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 11/18/2010 **Total Dsgn Cap:**
Population: 30 **Surveyor:** GARY KOBZEFF **Total Emerg Cap:**
Oper Period: 5/1 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	VELLINGA, MATT W	FOREST ENGIN	435-896-9233	435-896-9233	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unknown	0	1
			1 Total Svc Connections

Storage

Total Storage: 7,500 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	5,000 GAL	Steel		A	NO
ST002	STORAGE FACILITY ST002	Ground	2,500 GAL	Steel		A	NO
ST003	STORAGE FACILITY ST003 (DELETE	Ground		Steel		I	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	GOOSEBERRY CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	GOOSEBERRY SPRING	Active	SP				Yes	GW	Seasonal	5/1 to 9/30	

*Reports measured flow for wells, approved design capacity for all other sources.